



- 19,000-volt output for smoother ignition
- Solid state technology yields high performance, long life and durability
- Constant-duty rated
- Low current draw saves electricity
- Epoxy sealant provides water resistance and heat dissipation
- Consistent voltage output across a wide range of input voltages

Ignitor Model	41000
Power Input	120 VAC, 60 HZ, 40 VA
Ignitor Output	19 KV, 35 mA RMS
Secondary Grounding	Midpoint
Operating Temperature Limits	+32°F to +140°F
Storage Temperature Limits	-40°F to +185°F
Agencies	UL Recognized U.S. and Canada

MODEL 41000 Electronic Ignitor

19-KV continuous-duty

Data Sheet

Installing and wiring

WARNING Carlin ignitors and ignitor kits must be installed and serviced only by a qualified burner service technician. Always disconnect power source before wiring to avoid electrical shock or damage to electrical components.

- Carlin 41000 series ignitors can be mounted directly on top of the burner housing or other location, in the same manner as standard transformers.
- Disconnect electrical power to the burner. Disconnect wires from primary control to existing ignition transformer or ignitor.
- 3. Remove any screws securing ignition transformer or ignitor.
- 4. Observe the routing of electrical wiring from burner junction box to ignition transformer or ignitor.
- 5. Remove existing ignition transformer or ignitor.
- Select and install the appropriate terminals/springs based on the burner application. If the appropriate terminals are not included, remove and reuse the terminals from the ignitor being replaced.

IMPORTANT: Make sure to align terminals so that they make good contact with the electrode rods. In some cases properly aligned terminals will not be parallel to each other.

- Install new ignitor, reversing the above steps. Install, connect and route the ignitor wiring the same as the original ignition transformer or ignitor wiring was installed.
- Make sure the ignitor is firmly attached and that all electrical connections meet local codes before applying power.

Field check

WARNING Never test an ignitor by placing a screw-driver (or other metallic object) across the high voltage clips.

TECH SUPPORT HOTLINE 800-989-2275



Carlin Combustion Technology, Inc.

126 Bailey Road North Haven, CT 06473 e-mail us at: info@carlincombustion.com

Phone 203–680–9401 Fax 203–764–1714 visit our website: www.carlincombustion.com