INSTALLATION INSTRUCTIONS CHIMNEY ADAPTER KIT NAHA00301DH & NAHA00401DH

NOTE: For the application of an 80%, 33.3 inch (846mm), multipoise, non-condensing furnace in a Masonry Chimney

NOTE: Read the entire instruction manual before starting the installation. **KEEP THESE INSTRUCTIONS WITH THE FURNACE.**

PERSONAL INJURY HAZARD

Failure to follow this caution may result in personal injury.

C.S.A design-certified furnaces for use with chimney adapter kits on masonry chimneys are identified on their rating plates. These markings identify which chimney adapter kit number is permitted to be used with each furnace model number. Chimney adapter kits are for use with ONLY furnaces having factory-authorized chimney adapter kit numbers marked on the furnaces.

SAFETY CONSIDERATIONS

Installing and servicing heating equipment can be hazardous due to gas and electrical components. Only trained and qualified personnel should install, repair, or service heating equipment.

Untrained personnel can perform basic maintenance functions such as cleaning and replacing air filters. All other operations must be performed by trained service personnel. When working on heating equipment, observe precautions in the literature, on tags, and on labels attached to or shipped with the unit, and other safety precautions that may apply.

Follow all safety codes. In the United States, follow all safety codes including the National Fuel Gas Code (NFGC) NFPA 54/ANSI Z223.1.

Wear safety glasses and work gloves. Have a fire extinguisher available during start-up, adjustment procedures, and service calls.

Recognize safety information. This is the safety-alert

symbol Δ . When you see this symbol on the furnace and in instructions or manuals, be alert to the potential for personal injury.

Understand the signal words DANGER, WARNING, CAUTION, and NOTE. The words DANGER, WARNING, and CAUTION are used with the safety-alert symbol. DANGER identifies the most serious hazards which will result in severe personal injury or death. WARNING signifies hazards which could result in personal injury or death. CAUTION is used to identify unsafe practices which would result in minor personal injury, or product and property damage. NOTE is used to highlight suggestions which will result in enhanced installation, reliability, or operation.

MASONRY CHIMNEY APPLICATIONS

These kits and furnaces shall be applied in accordance with the following section titled Chimney Adapter Application Requirements. The Masonry Chimney Application Requirements section with Tables A and B inside the back page of this instruction identifies a very small number of exterior masonry chimney applications that are permitted without the use of the chimney adapter kit.

CHIMNEY ADAPTER APPLICATION REQUIREMENTS

This chimney adapter kit is permitted in accordance with NFGC as an ALTERNATIVE VENTING DESIGN. The requirements that follow in part A apply to both single-furnace and multiple-appliance applications. After completing part A, continue to part B for a single furnace application, or continue to part C for a multiple appliance application. After completing part B or C, continue to the INSTALLATION OF CHIMNEY ADAPTER section.

A. SINGLE FURNACE and MULTIPLE APPLIANCES

(Single furnace, and single furnace and draft hood-equipped water heater(s) vented into a chimney.)

- 1. This kit is permitted to be used in any building in which the space surrounding the furnace is not depressurized by more than 0.02 In. W.C. (5Pa) below outdoor pressure by equipment such as exhaust fans and clothes dryers.
- 2. Temperature of air surrounding furnace and vent connector(s) shall be $60^{\circ}F$ ($42^{\circ}C$) or warmer.
- 3. Furnace rating plate is marked with kit number that is permitted to be used.
- 4. Chimney construction shall be in good condition and shall conform to the Standard for Chimneys, Fireplaces, Vents, and Solid Fuel Burning Appliances NFPA 211 in the United States. See inspection chart on next page.
- 5. High altitude: Although appliance input is derated starting at 2000 ft altitude, use sea level input for all altitudes in this chimney sizing instruction.
- 6. Furnace vent connector lateral length, clay tile liner size, and chimney height shall conform to Table 2.
- 7. Maintain required clearance to combustible materials. See furnace for Minimum -Clearances-to-Combustible-Construction label, which includes minimum clearance to chimney adapter.
- 8. Appliance application and operation has significant impact on successful chimney performance. Follow furnace installation instructions in general and, in particular, the APPLIANCE APPLICATION REQUIREMENTS in the VENTING REQUIREMENTS section. See the NFGC or authority having jurisdiction for all other venting requirements.

| Table 1 | Kit Usage |
|--------------|------------------------------------|
| KIT PART NO. | USED ON |
| NAHA00301DH | 135,000 BTUH's equal to or greater |
| NAHA00401DH | Up to or equal to 110,000 BTUH's |

Table 2 – Chimney Requirements

| FURNACE MODEL SIZES | CHIMNEY ADAPTER KIT NUMBER | FURNACE VENT CONNECTOR LATERAL MAXIMUM LENGTH FT (M) | CHIMNEY CLAY TILE LINER MAXIMUM NOMINAL SIZE OR INSIDE AREA IN OR IN ² (MM or MM ²) | CHIMNEY MAXIMUM HEIGHT FT (M) |
|---------------------------|-------------------------------|--|--|--|
| 45,000 | | 9 (3) | 8 X 8 or 42.7 (203 X 203 or 27548) | 30 (9) |
| 45,000 | | 9 (3) | 8 X 12 or 63.6 (203 X 305 or 41032) | 25 (8) |
| 70,000 | NAHA00401DH | 9 (3) | 8 X 8 or 42.7 (203 X 203 or 27548) | 30 (9) |
| 70,000 | NARA00401DR | 9 (3) | 8 X 12 or 63.6 (203 X 305 or 41032) | 25 (8) |
| 90,000 | | 9 (3) | 8 X 12 or 63.6 (203 X 305 or 41032) | 35 (11) |
| 110,000 | | 9 (3) | 8 X 12 or 63.6 (203 X 305 or 41032) | 35 (11) |
| 135,000 | NAHA00301DH | 10 (3) | 12 X 12 or 83.3 (305 X 305 or 53742) | 35 (11) |
| 155,000 | NATA00301DH | 10 (3) | 12 X 12 or 83.3 (305 X 305 or 53742) | 35 (11) |
| · | | Table 2 Dermitted Ch | impov Location | |

Table 3 – Permitted Chimney Location

| MINIMUM 99% WINTER DESIGN TEMPERATURE* | PERMITTED CHIMNEY LOCATION |
|--|----------------------------|
| -25°F (-32°C) or Warmer | Interior Masonry Chimney† |
| +17°F (-8°C) or Warmer | Exterior Masonry Chimneys‡ |

* The 99% Winter Design Dry-Bulb (db) temperatures are found in the 2005 ASHRAE Fundamentals Handbook CD and Chapter 28. Fig. G.2.4 in the NFPA54/ANSI Z223.1-2009 (Appendix G) also provides winter design temperatures for some locations.

†Chimneys not exposed to the outdoors below the roof-line.

‡Chimneys with one or more sides exposed to the outdoors below the roof line.

Table 4 – Single–Furnace – Masonry Chimney Flue Capacity with Type–B Double–Wall Vent Connector

| VENT | | MINIMU | JM "NAT MAX' INTE | RNAL AREA OF MA | SONRY CHIMNEY F | LUE, SQUARE IN | |
|---------|---------|--------|-------------------|-------------------|------------------|----------------|-----|
| HEIGHT | LATERAL | 28 | 38 | 50 | 63 | 78 | 95 |
| н | FT (M) | | FURNACE INPU | T RATING IN THOUS | SANDS OF BTU PER | RHOUR | |
| FT (M) | | NAT | NAT | NAT | NAT | NAT | NAT |
| C (0) | 2 (.6) | 86 | 130 | 180 | 247 | 320 | 401 |
| 6 (2) | 5 (2) | 82 | 117 | 165 | 231 | 298 | 376 |
| | 2 (.6) | 93 | 145 | 198 | 266 | 350 | 446 |
| 8 (2) | 5 (2) | 88 | 134 | 183 | 247 | 328 | 423 |
| () | 8 (2) | 83 | 127 | 175 | 239 | 318 | 410 |
| | 2 (.6) | 103 | 162 | 221 | 298 | 388 | 491 |
| 10 (3) | 5 (2) | 96 | 148 | 204 | 277 | 365 | 466 |
| ., | 10 (3) | 87 | 139 | 191 | 263 | 347 | 444 |
| | 2 (.6) | 114 | 179 | 250 | 336 | 441 | 562 |
| 15 (5) | 5 (2) | 107 | 164 | 231 | 313 | 416 | 513 |
| . , | 10 (3) | 97 | 153 | 216 | 296 | 394 | 567 |
| | 2 (.6) | 124 | 201 | 274 | 375 | 491 | 627 |
| 20 (6) | 5 (2) | 116 | 184 | 254 | 350 | 463 | 597 |
| . , | 10 (3) | 107 | 172 | 237 | 332 | 440 | 566 |
| | 2 (.6) | 137 | 216 | 303 | 421 | 558 | 717 |
| 30 (9) | 5 (2) | 128 | 198 | 281 | 393 | 526 | 683 |
| | 10 (3) | 115 | 184 | 236 | 373 | 500 | 648 |
| | 2 (.6) | 143 | 168 | 315 | 435 | 577 | 741 |
| 35 (11) | 5 (2) | 134 | 206 | 291 | 406 | 544 | 706 |
| | 10 (3) | 121 | 192 | 273 | 386 | 517 | 669 |

NOTE: Table 4 was extracted from "NAT Max" columns in Table 13.1(c) in Chapter 13 of NFPA54/ANSI Z223.1–2009 in United States, or Table 1 C.5 of Appendix C in CAN/CSA–B149.1–10 in Canada.

Table 5 – Permitted Vent Material

| MINIMUM 99% WINTER DESIGN TEMPERATURE* | CHIMNEY LOCATION | FURNACE VENT CONNECTOR MATERIAL | WATER HEATER VENT CONNECTOR MATERIAL |
|---|----------------------------|---|---|
| −25°F (−32°C) to −10° (−23°C) | Interior Masonry Chimneys† | Listed Type—B Double—Wall Metal Pipe | Listed Type—B Double—Wall Metal Pipe or Single—Wall Gal- vanized Steel Pipe |
| | Exterior Masonry Chimneys‡ | Not Permitted | Not Permitted |
| 10°E (22°C) or Warmar | Interior Masonry Chimneys† | Listed Type—B Double—Wall Metal Pipe or Single—Wall Gal- vanized Steel Pipe | Listed Type–B Double–Wall Metal Pipe or Single–Wall Gal- vanized Steel Pipe |
| –10°F (–23°C) or Warmer | Exterior Masonry Chimneys‡ | Listed Type-B Double-Wall Metal Pipe | Listed Type–B Double–Wall Metal Pipe or Single–Wall Gal- vanized Steel Pipe |

*The 99% Winter Design Dry–Bulb (db) temperatures are found in the 2005 ASHRAE Fundamentals Handbook CD and Chapter 28. Fig. G.2.4 in NFPA54/ANSI Z223.1–2009 (Appendix G) also provides winter design temperatures for some locations.

†Chimneys not exposed to outdoors below roof-line.

‡Chimneys with 1 or more sides exposed to outdoors below roof-line.

Table 6 – Max Water Heater Input

| VENT HEIGHT H – FT (M) | | | 6 (2) | | 1 | 3 (2.5) |) | | 10 (3) | | 1 | 5 (4.5 | i) | | 20 (6) | | | 30 (9) | | 5 | 60 (15 |) | 10 | 00 (30 |)) |
|---------------------------------------|-----|----|-------|----|----|---------|----|----|--------|----|----|--------|----|----|--------|----|----|--------|----|----|--------|----|----|--------|----|
| 4-inch dia. (102 mm) Connector Rise R | Ft. | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 |
| | (M) | .3 | .6 | .9 | .3 | .6 | .9 | .3 | .6 | .9 | .3 | .6 | .9 | .3 | .6 | .9 | .3 | .6 | .9 | .3 | .6 | .9 | .3 | .6 | .9 |
| Water Heater Maximum Input Rating in | В | 40 | 52 | 61 | 41 | 53 | 62 | 42 | 54 | 63 | 44 | 55 | 64 | 46 | 56 | 65 | 48 | 58 | 66 | 51 | 61 | 69 | 50 | 60 | 68 |
| Thousands of BTU per Hour | S | 39 | 52 | 61 | 40 | 52 | 62 | 41 | 53 | 62 | 43 | 54 | 63 | 45 | 57 | 65 | 47 | 57 | 65 | 50 | 60 | 68 | 49 | 59 | 67 |

B=Listed Type-B Double-Wall metal pipe. S=Single-Wall galvanized-steel pipe. These rise requirements are based on NFGC and NSCNGPIC.



A10133

Table 7 – Minimum Masonry Chimney Internal Area (Multiple Appliances)

| | MINIMUM "NAT+NAT" INTERNAL AREA OF MASONRY CHIMNEY FLUE, SQ. IN. (SQ. MM) | | | | | | | | | | | | |
|-------------|---|--------------------|-------------------|--------------------|-----------------|-------------|--|--|--|--|--|--|--|
| Vent Height | 28 (18064) | 38 (24516) | 50 (32258) | 63 (40645) | 78 (50322) | 113 (72903) | | | | | | | |
| н | | Combined Appliance | e Maximum Input R | ating in Thousands | of Btu per Hour | I | | | | | | | |
| Ft. (M) | NAT +NAT | NAT +NAT | NAT +NAT | NAT +NAT | NAT +NAT | NAT +NAT | | | | | | | |
| 6 (2) | NP | 103 | 143 | 188 | 246 | NP | | | | | | | |
| 8 (2) | NP | 119 | 163 | 218 | 278 | 408 | | | | | | | |
| 10 (3) | NP | 131 | 177 | 236 | 302 | 454 | | | | | | | |
| 15 (5) | 106 | 152 | 212 | 283 | 365 | 546 | | | | | | | |
| 20 (6) | 122 | 172 | 243 | 325 | 419 | 648 | | | | | | | |
| 30 (9) | 137 | 198 | 278 | 381 | 496 | 749 | | | | | | | |
| 35 (11) | NP | NP | 291 | 401 | 524 | 792 | | | | | | | |

NP - Not Permitted

Table 8 – Permitted Exceptions to Minimum 99% Winter Design Temperature and Furnace Connector Diameter

| _ | Chimney Clay Tile Liner Nominal Size or Inside Area In. or Sq. In (mm or Sq. mm) | | | | | | | | | | | | | |
|---------------------------|---|--------------------------------|----------|-------------------|------------------------------------|-----------------|---|------------|---------|--|--|--|--|--|
| Furnace Model Sizes | | x 8 or 42.7 x 203 or 27548) | | | 8 x 12 or 63.6 3 x 305 or 41032 | | 12 x 12 or 83.3 (305 x 305 or 53742) | | | | | | | |
| Sizes | | | | Furnace Type-B Ve | nt Connector Dia | ameter In. (mm) | • | | | | | | | |
| | 6 (152) | 5 (127) | 4 (102) | 6 (152) | 5 (127) | 4 (102) | 7 (178) | 6 (152) | 5 (127) | | | | | |
| 70,000 | -10 (-23)‡‡ | -10 (-23) | +5 (15)* | -10 (-23)**†† | -10 (-23) | -10 (-23)* | NP | NP | NP | | | | | |
| 90,000 | -10 (-23)†† | -10 (-23)† | NP | -10 (-23)†† | -10 (-23)† | NP | NP | NP | NP | | | | | |
| 110,000 | -10 (-23)‡ | NP | NP | -10 (-23)‡ | NP | NP | NP | NP | NP | | | | | |
| 135,000 | -10 (-23)*†,†† | NP | NP | -10 (-23)*†† | NP | NP | -10 (-23)†† | -10 (-23)* | NP | | | | | |
| 155,000 | NP | NP | NP | NP | NP | NP | -10 (-23) | NP | NP | | | | | |

NP = Not Permitted

Temperatures in parentheses are Celsius temperatures.

* Furnace connector rise shall be at least 3 ft. (.9 M)

†Chimney height shall be at least 10 ft. A higher chimney height is required, if the furnace installation instructions specify a higher chimney height.

‡Furnace connector rise shall be at least 2 ft or chimney height shall be at least 15 ft. (5 M)

** 6-in. X 5-in. (152 X 127 mm) or 6-in. X 4-in. (152 X 102 mm) tapered furnace vent connector decreaser is permitted at chimney inlet opening. However, better resistance to chimney condensation will result, if connector diameter is not reduced.

++4-in. X 3-in. (102 X 76 mm) tapered water heater vent connector decreaser is permitted at chimney inlet opening. However, better resistance to chimney condensation will result, if connector diameter is not reduced.

‡‡Either ** or †† is permitted, but not both.

B. SINGLE FURNACE

(Single furnace without a draft hood-equipped water heater vented into a chimney.)

- 1. The 99 percent winter design temperature* shall determine permitted locations for clay tile lined masonry chimneys as shown in Table 3 :
- 2. Type B double wall metal vent (with up to 4 elbows) shall be used exclusively for furnace vent connector.
- 3. Furnace vent connector shall be same size as Chimney Adapter outlet.
- 4. See Table 2 for maximum length of furnace vent connector lateral.

NOTE: See Figure 1 while reviewing the following requirements.

- 5. The minimum chimney size shall conform to Table 4.
- 6. See Table 2 for maximum chimney size and maximum chimney height.

C. MULTIPLE APPLIANCES

(Single furnace common-vented with a draft hood-equipped water heater(s) into a chimney.)

- 1. The minimum 99 percent winter design temperature* and chimney location shall determine permitted vent connector material as shown in Table 5:
- 2. Furnace vent connector rises shall not exceed 3 ft. (.9M)
- 3. An operational draft hood-equipped water heater shall be common-vented with furnace. Additional

draft hood-equipped appliances are permitted to be common-vented with furnace.

- 4. Each vent connector is permitted up to 4 elbows.
- 5. Furnace vent connector shall be same size as Chimney Adapter outlet.
- 6. Water heater vent connector shall be 4-in. (102 mm)diameter with no more than 6 ft. (2 M) of lateral (horizontal connector length), with water heater draft hood outlet sizes of 3- and 4-in. (76 and 102 mm) diameter. Use a 3- X 4-in. (76 X 102 mm)vent increaser with a 3-in. (76 mm) draft hood outlet.
- 7. Water heater gas inputs* shall not exceed the following rates as shown in Table 6.

NOTE: See Figure 1 while reviewing the following requirements.

- 8. Minimum chimney size shall conform to "NAT+NAT" columns for common vent capacity in Table 13.2c in of NFPA54/ANSI Z223.1–2009 in United States. The chimney sizing requirements in Table 7 were extracted from these codes.
- Permitted exceptions to -10°F (-23°C) minimum 99 percent winter design temperature and furnace connector diameters are provided in Table 8. If Table 8 permits a furnace connector size that is smaller than the chimney adapter outlet, a tapered decreaser is permitted at the chimney adapter outlet.
- Manifolded common-vent connectors: See NFPA54/ANSI Z223.1 in USA. For chimney heights of 8 ft or more, Type-B manifolded common-vent connectors with no elbows are permitted. The

manifolded common-vent connector diameter shall be 1 in. (25 mm) greater than required furnace vent connector size. The combined horizontal length of longest vent connector (furnace or water heater) plus manifolded common-vent connector shall not exceed vent connector lateral specified in section A.6. Each connector is permitted up to 2 elbows. No exceptions from Table 8 are permitted. The minimum winter design temperature permitted with manifolded common-vent connector is $-10^{\circ}F$ ($-23^{\circ}C$).

INSTALLATION OF CHIMNEY ADAPTER

- 1. Turn off gas supply at manual gas valve before turning off electric power supply to furnace.
- 2. Turn off electric power supply to furnace at disconnect switch.

A WARNING

ELECTRICAL SHOCK HAZARD

Failure to follow this warning could result in personal injury or death.

Before installing, modifying, or servicing system, always turn off main power to system and tag disconnect switch with a suitable warning label. There may be more than one disconnect.

- 3. The chimney adapters must always be installed for vertical flow of vent gas from bottom to top of chimney adapter.
- 4. UPFLOW AND HORIZONTAL AIR-FLOW APPLICATIONS NOT NEEDING STRAIGHT VENT PIPE INTERNAL TO FURNACE

KIT NO. NAHA00401DH: Attach chimney adapter to furnace flue elbow with 2 sheet metal screws (field–supplied) through two 1/8–in. (3 mm) holes at inlet (small end) of chimney adapter. (See Figure 2 or Figure 3) If a 1/8–in. (3 mm) hole at inlet is not accessible, remove three screws that hold elbow to inducer, attach chimney adapter to elbow, then reattach elbow to inducer.

KIT NO. NAHA00301DH: Use same procedure as above, except a standard 4–in. dia. to 5–in. dia. (102 to 127 mm) vent pipe increaser (field–supplied) is required between furnace elbow and chimney adapter.

DOWNFLOW AND HORIZONTAL AIR-FLOW APPLICATIONS HAVING A STRAIGHT VENT PIPE INTERNAL TO FURNACE

KIT NO. NAHA00401DH: Complete installation of flue pipe (and elbows) to exit furnace casing. If downflow furnace flue pipe exits casing through lower–left door opening, route the flue pipe through an accessory vent guard external to the casing. Attach chimney adapter to furnace flue where it exits the furnace casing or vent guard with three sheet metal screws (field–supplied) through two factory–punched 1/8–in. (3 mm)holes and a third fielded–drilled 1/8–in. (3 mm) hole at inlet (small end) of chimney adapter. Third hole should be 90° from other two holes.

KIT NO. NAHA00301DH: Use same procedure as above for NAHA00401DH, except a standard 4-in. dia.-to-5-in. (102 to 127 mm) dia. vent pipe increaser (field-supplied) is required between the furnace flue and the chimney adapter.

5. Remove lock nut from fitting on free end of electrical conduit attached to chimney adapter. Route wire ends through a 7/8-in. (22 mm) hole in furnace

casing near the chimney adapter. Secure conduit to furnace with lock nut. If Vent Guard is used on downflow furnace, cut a notch in Vent Guard flange to provide access to 7/8–in. (22 mm) hole in furnace casing for conduit attachment.

6. See furnace casing for wiring diagram. Find furnace red wires that connect to draft safeguard switch (DSS). Disconnect red wire with insulated, female, 3/16-in. (8 mm) quick-connect terminal from DSS, and connect this red wire to orange wire from blocked vent shutoff switch (BVSS) of chimney adapter that has insulated, male, 3/16-in. (8 mm) quick-connect terminal. Male and female 3/16-in. (8 mm) terminals must be oriented so that insulators fit together. Connect other chimney adapter BVSS orange wire to DSS terminal from which red wire was disconnected. Position orange wire terminal similar to remaining red wire terminal on DSS so that orange wire is directed away from hot elbow. The BVSS should be in series with the DSS.

NOTE: For applications where the chimney adapter wire leads will not reach the DSS, use the factory-supplied extension wires between the chimney adapter BVSS leads and the DSS. A metal wire-routing clip is included in the kit to secure the orange extension wires away from hot surfaces and rotating parts.

- 7. No other wire connection changes should be made for chimney adapter. Be certain that no terminals can be shorted to other circuits or to any grounded parts.
- 8. Refer to Figure 1. Secure a Type-B draft hood connector to top of chimney adapter with 3 sheet metal screws (field-supplied). Install Type-B double-wall metal vent connector from draft hood connector to chimney flue opening in accordance pipe manufacturer's Installation with vent Instructions. The horizontal portion of venting system shall maintain a minimum of 1/4-in. upward slope per linear foot away from furnace, and shall be rigidly supported every 5 ft. or less with hangers and straps to ensure that there will be no movement after installation. The connector shall conform to size. rise, and lateral requirements under Venting Requirements of these instructions. Do NOT use the NFGC or NSCNGPIC vent connector sizing requirements.
- 9. Complete installation of water heater Type-B double-wall vent connector in same manner as used for furnace connector, except that a chimney adapter is not required at Type-B draft hood connector for water heater. (Not required for single appliance, Venting Requirements Section B.)

START-UP, ADJUSTMENT, AND SAFETY CHECK

 Complete Start-Up, Adjustment, and Safety Check in furnace Installation Instructions. Adjust furnace air temperature rise to be near high end of air temperature rise range specified on furnace rating plate (without exceeding high end of rise range). A higher air temperature rise reduces chimney condensation. While doing furnace check, the following steps shall be performed with each appliance that is connected to common vented chimney. Put each appliance in operation while other appliance(s) are not in operation.

- a. Inspect venting system for blockage or restriction, leakage, corrosion, and other deficiencies that could cause an unsafe condition.
- b. Insofar as practical, close all building doors and windows, and all doors between space in which appliances are located and other spaces of building. Turn on clothes dryer and any appliance not connected to this chimney flue. Turn on all exhaust fans such as range hoods and bathroom exhausts, so they will operate at maximum speed. Do not operate a summer exhaust fan. Close fireplace dampers.
- c. Follow operating instructions for each appliance being checked. Adjust each thermostat so appliance will operate continuously.
- d. Test for vent gas spillage at water heater draft hood (when applicable) and at furnace chimney adapter relief openings after 5 minutes of main burner operation. Use the flame of a match or candle.
- e. Operate ALL appliances that are common-vent connected to chimney flue, and again test for vent gas spillage.
- f. If improper venting is observed during any of above tests (e.g., vent gas spillage at water heater draft hood or furnace chimney adapter, or leakage from vent system), the common-venting chimney system must be corrected.
- g. After it has been determined that each appliance properly vents when tested as outlined above, return doors, windows, exhaust fans, fireplace

dampers, and any other gas-burning appliances to their previous conditions of use.

- 2. Check chimney adapter BVSS. This test is required, in addition to the test of the DSS required by the furnace installation instructions. The purpose of the BVSS is to cause safe shutdown of furnace, if furnace vent connector or chimney becomes blocked.
 - a. Disconnect power to furnace, and remove vent connector from chimney adapter. Be sure to allow time for vent pipe to cool down before handling pipe.
 - b. Place jumper wire across DSS terminals to electrically by-pass DSS so that if DSS opens, furnace does not shutdown until BVSS opens.
 - c. Restore power to furnace and set room thermostat $5^{\circ}F$ (-15 $^{\circ}C$) above room temperature.
 - d. After normal start-up, allow furnace to operate for 2 minutes, then block chimney adapter outlet 100 percent. Furnace should shut off within 2 minutes.
 - e. REMOVE JUMPER WIRE FROM DRAFT SAFEGUARD SWITCH!
 - f. Remove blockage and reconnect vent connector to chimney adapter.
 - g. Wait 5 minutes, then reset BVSS and DSS.
- 3. With furnace blower operating, check for air leakage from supply-air plenum or coil casing that could interfere with BVSS operation. If air leaks are found they must be properly sealed.
- 4. Leave Installation Instructions for chimney adapter and for furnace near furnace.



Figure 1 – Furnace and Water Heater Vent Connectors, Chimney Adapter, and Chimney



A10234

Figure 4 – Chimney Adapter Secured to Upflow Furnace Flue Collar



Figure 5 – Chimney Adapter Secured to Upflow Furnace Flue Collar (Sizes of 132,000 and greater Btuh input)



Figure 6 – Chimney Adapter Secured to Flue Collar, Internal Flue Pipe, and Vent Elbow on Horizontal–Right Furnace



A08196

Figure 7 – Chimney Adapter Secured to Upflow Furnace Flue Collar



A08195

MASONRY CHIMNEY APPLICATION REQUIREMENTS

If a clay tile-lined masonry chimney is used, an alternative venting design might be required, such as a listed chimney lining system or this listed chimney adapter kit. ONE OF THE FOLLOWING METHODS SHALL BE USED TO DETERMINE IF AN ALTERNATIVE VENTING DESIGN IS NOT REQUIRED.

In the USA – Refer to Sections 13.1.11 and 13.2.22 of NFPA54/ANSI Z223.1–2009 or the authority having jurisdiction to determine whether relining is required. If relining is required, use a properly sized listed metal liner, Type–B vent, or a listed alternative venting design, such as this listed chimney adapter kit (with a furnace listed for use with this kit), a listed chimney lining system, or a Type–B common vent.

A 78 or 80 percent AFUE, hot surface ignition, Category I, fan-assisted furnace is permitted to be vented into a clay tile-lined masonry chimney that is exposed to the outdoors below the roof line, provided:

<u>Multiple Appliances</u> – (A single furnace common-vented with a draft hood-equipped water heater(s) into a chimney.)

- 1. Vent connector is Type-B double-wall, and
- 2. The furnace is common vented with at least one draft hood-equipped appliance, and
- 3. The combined appliance input rating is less than the maximum capacity given in Table 9, and

- 4. Input rating of each space heating appliance is greater than minimum input rating given in Table 10 and
- 5. The authority having jurisdiction approves.

If all of these conditions cannot be met, an alternative venting design is required, such as this listed chimney adapter kit (with a furnace listed for use with this kit), a listed chimney lining system, or a Type-B common vent.

<u>Single Appliance</u> – (A single furnace vented into a chimney.) – Category I, fan assisted furnaces without draft hoods are not permitted to be vented into clay tile–lined masonry chimneys that are exposed to the outdoors below the roof line.

Table 9 – Combined Appliance Maximum Input Rating in Thousands of Btu per Hr

| VENT | INTERNAL AREA OF CHIMNEY IN. ² (mm ²⁾ | | | | | | | | | |
|------------------|--|---------------|---------------|---------------|--|--|--|--|--|--|
| HEIGHT FT (M) | 12 (7742) | 19 (12258) | 28 (18064) | 38 (24516) | | | | | | |
| 6 (1.8) | 74 | 119 | 178 | 257 | | | | | | |
| 8 (2.4) | 80 | 130 | 193 | 279 | | | | | | |
| 10 (3) | 84 | 138 | 207 | 299 | | | | | | |
| 15 (5) | NR | 152 | 233 | 334 | | | | | | |
| 20 (6) | NR | NR | 250 | 368 | | | | | | |
| 30 (9) | NR | NR | NR | 404 | | | | | | |

Table 10 – Minimum Allowable Input Rating of Space– Heating Appliances in Thousands of Btu per Hr

| | VENT HEIGHT | INT | ERNAL ARE IN. ² (I | | IEY | |
|---|----------------|--------------|---|---------------|---------------|--|
| | FT. (M) | 12 (7742) | 19 (12258) | 28 (18064) | 38 (24516) | |
| _ | | | 9% Winter D 17 to 26°F (- | | | |
| 17 to 26°F (−8 to −3°C) | 6 (2) | 0 | 55 | 99 | 141 | |
| 130 | 8 (2) | 52 | 74 | 111 | 154 | |
| 2 Q | 10 (3) | NR | 90 | 125 | 169 | |
| ÷ ® [| 15 (5) | NR | NR | 167 | 212 | |
| - | 20 (6) | NR | NR | 212 | 258 | |
| | 30 (9) | NR | NR | NR | 362 | |
| _ | | | 9% Winter D 5 to 16°F (-1 | | rature: | |
| L O | 6 (2) | NR | 78 | 121 | 166 | |
| 0° | 8 (2) | NR | 94 | 135 | 182 | |
| 5 to 16°F -15 to -9°C) | 10 (3) | NR | 111 | 149 | 198 | |
| <u>с</u> 1 2 | 15 (5) | NR | NR | 193 | 247 | |
| <u> </u> | 20 (6) | NR | NR | NR | 293 | |
| | 30 (9) | NR | NR | NR | 377 | |
| 0 | | | 9% Winter D 10 to 4°F (-2 | | | |
| щ | 6 (2) | NR | NR | 145 | 196 | |
| −10 to 4°F 23 to −16°C) | 8 (2) | NR | NR | 159 | 213 | |
| 4 0 4 0 | 10 (3) | NR | NR | 175 | 231 | |
| Γ Ω | 15 (5) | NR | NR | NR | 283 | |
| L | 20 (6) | NR | NR | NR | 333 | |
| | 30 (9) | NR | NR | NR | NR | |
| —11 °F or lower (-24°C or lower) | | –11°F or l | inter Design ⁻ ower (–24°C ed for any ve | or lower)* | | |

*The 99% Winter Design Dry–Bulb (db) temperatures are found in the 2005 ASHRAE Fundamentals Handbook CD and Chapter 28.

